


**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE**

No. - 06Date :- 12.05.2026

It is certified that an inspection team headed by Md Munan Alam, Assistant Engineer
 (Name of Officers
 With Designation) from Public Health Division Khagaria (Name of
 Department/ Office) Inspected the Rose Bud Academy Gaushala Road
Khagaria (Name & Address of
 the School) on 11.05.2026 and Found that the Rose Bud Academy
 (Name of School) has safe
 drinking water facilities for the students and members of staff of the institution and is
 maintaining the hygienic sanitation condition in the school building & the campus as per
 the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of Six monthSignature with seal : 

Name :-

Md Munan Alam

Designation :-

Assistant EngineerP.H. sub Division Khagaria

To

Rose Bud Academy,Gaushala Road, KhagariaBihar

(Name & Address of the Institution)

Newton
MANAGER
ROSE BUD ACADEMY
KHAGARIA

R. Singh
PRINCIPAL
Rose Bud Academy
Gaushala Road, Khagaria
AFFN. NO.-330649

Government of Bihar
District Level Water Testing Laboratory, Khagaria
P.H.Division, Khagaria

Report No:- 06 Date- 12.05.2026 Date of Sampling :- 11.05.2026
 Ref No :-RBA/Govt./03/2026-27 Sample Received in Lab :- 11.05.2026
 SBD No :-..... Sample Collected By:- Md Junaid Alam
 Agency Name :-Rose Bud Academy Source of Sample :- Sample no(1) RO Water & (2) Raw Water

Water Test Report

Sl. No.	Sample Code	Location			Parameters Mg/l (ppm)										Test	Bacteria (H2S Vial)
		Block	Panchayat	Ward	pH	Turb	TDS	TH	Ca	Mg	Cl	Alka	Fe			
1	KHRW/26-27/105	Rose Bud Academy Gaushala Road, Khagaria			7.12	1	254	167.66	33.97	20.09	29.68	189.88	0.74	Aggreable	(-) ve	
2	KHRW/26-27/106	Rose Bud Academy Gaushala Road, Khagaria			7.39	2	369	208.06	51.77	24.01	46.64	232.30	0.26	Aggreable	(-) ve	
Desirable Limit					6.5-8.5	1	500	200	75	30	250	200	1.0	Aggreable	(-) ve	
Permissible Limit* in absence of alternative source					NR	5	2000	600	200	100	1000	600	NR	Not Aggreable	(+) ve	

Note :- (1) Drinking Water Sepsification Second Revision IS : 10500: 2012
 (2) BDL= Below Dedection Limit.
 (3) NR = No Relaxtion.
 (4) Iron Colour Visual Method

1. The Results are reported Based on the Materials Received. 2 Sample will be Destroyed after 10 Days From the date of issue of the Test report subject to nature of Preparation unless otherwise Specified. 3 Sample will be preserved According to standard Method.

***** END OF TEST REPORT *****

12.05.26
 Lab Assistant
 DLWTL, Khagaria

Alwton
MANAGER
ROSE BUD ACADEMY
KHAGARIA

Kindh
PRINCIPAL
Rose Bud Academy
Gaushala Road, Khagaria
AFFN. NO.-330649